



TO WHOM IT MAY CONCERN

M/S FIRE GUARD SYNDICATE, of BB 12/13 Rabindra pally, Baguihati, Kolkata-700 059 was satisfactorily completed the sprinkler networking (Auto Water Suppression system) in Unitech Building 5th to 7th Floor, leased with TCS covering an area 251548 Sq ft within the time limit in terms of order no : TCSL/WO/Infospace-Kolkata(Lease-SEZ)/8591 & 8590 dt 29.01.2010 amounting Rs. 58,80,062/- (Material Supply Rs.47,60,604/- + Fire Fighting Works Labour Rs.11,19,558 /-).

The noted vendor tested the system with high pressure water and found every installation is properly done with IS Mark MS Pipe and IS Mark Sprinkler valve and no water is leaked and the system is working with full satisfaction. Moreover sprinkler was busted by creating manual heat when line was in auto mode the system correctly sprayed water covering a large area with full pressure.


FIRE ADVISOR

EASTERN REGION (INDIA)

TATA CONSULTING SERVICES



TATA CONSULTANCY SERVICES

Tata Consultancy Services Limited

Plot B1 Block EP Salt Lake Electronics Complex Sec-V Bidhan Nagar Kolkata 700 091 India
Tel +91 33 6636 9699 Fax +91 33 6636 9001 e-mail corporate.office@tcs.com website www.tcs.com
Registered Office Nirmal Building 9th Floor Nariman Point Mumbai - 400 021